



PRODUCT PERFORMANCE REPORT

Document ID 1534343111
 Issued on August 15th, 2018

PROJECT IDENTIFICATION - This product performance report is delivered for:

Name **Viacom VS**
 Company **Viacom VS**
 Project reference **Fujitsu Website**
 Project location **Serbia and Montenegro**

PRODUCT IDENTIFICATION

Certification Diploma N° **94.01.198**
 Brand **FUJITSU**
 Range **ASY**L**
 Product type **Comfort Air Conditioners / up to 12 kW / Air cooled / Split / Reverse cycle**
 Product reference **AOYG18LFC / ASYG18LFCA**

Important notice:

- I. Data featured in this report are valid at the date of issue. The scope of this product performance report does not include all certified data that can be checked at <http://www.eurovent-certification.com>
- II. This product performance report is valid only for above product features and should not be referred to as a Diploma.

FEATURE	VALUE	UNIT
Acoustic		
LwO env	65	dB(A)
Lw1 env	58	dB(A)
Bivalent Point		
Tbiv	-7	Å°C
COP @ Tbiv	2.25	
Ph TBiv	5.22	kW
General		
Mounting	Wall mounted	
MPS	230-1-50	
Refrigerant	R410A	
Refr. Line	5,0 m	m
Heating 14511		
Ph @+7	6.3	kW
COP @+7	3.68	
Heating Average Climate		
Pdesignh	5.9	kW
SCOP	3.87	
SCOP Class	A	
Qhe	2130.0	kWh/annum
Pck		
Pck	8.0	W
Poffc		



PRODUCT PERFORMANCE REPORT

Document ID 1534343111
 Issued on August 15th, 2018

FEATURE	VALUE	UNIT
Poff	7.0	W
Poffh		
Poffh	19.0	W
Psb		
Psb	7.0	W
Ptoc		
Pto	8.0	W
Seasonal Efficiency in Cooling		
Pdesignc	5.2	kW
SEER	6.94	
SEER Class	A++	
Qce	262.0	kWh/annum
Thermal		
EER @+35	3.42	
TOL Runing Test		
TOL	-15.0	Â°C
COP @ TOL	2.1	
Ph @ TOL	4.81	kW