



# PRODUCT PERFORMANCE RATING

Document ID 050520201626-12242327

Issued on 5 May 2020

This product is certified by Eurovent Certita Certification as mentioned on

**Certificate N° 94.01.198**

This document is valid at the date of issue - **Check the current validity on [www.eurovent-certification.com](http://www.eurovent-certification.com)**

Product	Air Conditioners / Climatiseurs (AC)
Product type	Comfort air conditioner below 12 kW/ air-cooled/ split/ reversible
Brand	FUJITSU
Range	ARY**L
Product référence	AOYG30LETL/ARYG30LMLE

This performance certificate is delivered for the following project:

Project Name	Company	Project reference	Project location
kanalske		BEOGRAD	Serbia

FEATURE	VALUE	UNIT
<b>STANDARD COOLING/COOLING PL COND A</b>		
Pc	8.50	kW
Pec	2.65	kW
EER	3.21	



# PRODUCT PERFORMANCE RATING

Document ID 050520201626-12242327

Issued on 5 May 2020

This product is certified by Eurovent Certita Certification as mentioned on

**Certificate N° 94.01.198**

This document is valid at the date of issue - **Check the current validity on [www.eurovent-certification.com](http://www.eurovent-certification.com)**

FEATURE	VALUE	UNIT
<b>STANDARD HEATING</b>		
Ph	10.00	kW
Peh	2.68	kW
COP	3.73	

FEATURE	VALUE	UNIT
<b>ACOUSTIC</b>		
LwO env	68	dB(A)
LwI1 duct	65	dB(A)

FEATURE	VALUE	UNIT
<b>COOLING PL CONDB</b>		
Pc @ 30°C	6.26	kW
EER @ 30°C	4.55	



# PRODUCT PERFORMANCE RATING

Document ID 050520201626-12242327

Issued on 5 May 2020

This product is certified by Eurovent Certita Certification as mentioned on

**Certificate N° 94.01.198**

This document is valid at the date of issue - **Check the current validity on [www.eurovent-certification.com](http://www.eurovent-certification.com)**

FEATURE	VALUE	UNIT
<b>COOLING PL CONDC</b>		
Pc @ 25°C	4.22	kW
EER @ 25°C	7.49	

FEATURE	VALUE	UNIT
<b>COOLING PL CONDD</b>		
Pc @ 20°C	4.38	kW
EER @ 20°C	9.88	

FEATURE	VALUE	UNIT
<b>SEASONAL EFFICIENCY IN COOLING</b>		
Pdesignc	8.50	kW
SEER	5.90	
Qce	504.00	kWh/annum
SEER Class	A+	



# PRODUCT PERFORMANCE RATING

Document ID 050520201626-12242327

Issued on 5 May 2020

This product is certified by Eurovent Certita Certification as mentioned on

**Certificate N° 94.01.198**

This document is valid at the date of issue - **Check the current validity on [www.eurovent-certification.com](http://www.eurovent-certification.com)**

FEATURE	VALUE	UNIT
<b>HEATING PL CONDA</b>		
Ph @ -7°C	7.08	kW
COP @ -7°C	2.73	

FEATURE	VALUE	UNIT
<b>HEATING PL CONDB</b>		
Ph @ +2°C	4.31	kW
COP @ 2°C	3.85	

FEATURE	VALUE	UNIT
<b>HEATING PL CONDC</b>		
Ph @ +7°C	3.17	kW
COP @ +7°C	5.01	

FEATURE	VALUE	UNIT
<b>HEATING PL CONDD</b>		
Ph @ +12°C	3.77	kW
COP @ +12°C	6.09	



# PRODUCT PERFORMANCE RATING

Document ID 050520201626-12242327

Issued on 5 May 2020

This product is certified by Eurovent Certita Certification as mentioned on

**Certificate N° 94.01.198**

This document is valid at the date of issue - **Check the current validity on [www.eurovent-certification.com](http://www.eurovent-certification.com)**

FEATURE	VALUE	UNIT
<b>HEATING AVERAGE CLIMATE</b>		
Pdesignh	8.00	kW
SCOP	3.90	
SCOP Class	A	
Qhe	2868.00	kWh/annum

FEATURE	VALUE	UNIT
<b>BIVALENT POINT</b>		
Tbiv	-7	°C
COP @ Tbiv	2.73	
Ph TBiv	7.08	kW

FEATURE	VALUE	UNIT
<b>TOL RUNING TEST</b>		
TOL	-15.00	°C
COP @ TOL	2.49	
Ph @ TOL	6.50	kW



# PRODUCT PERFORMANCE RATING

Document ID 050520201626-12242327

Issued on 5 May 2020

This product is certified by Eurovent Certita Certification as mentioned on

**Certificate N° 94.01.198**

This document is valid at the date of issue - **Check the current validity on [www.eurovent-certification.com](http://www.eurovent-certification.com)**

FEATURE	VALUE	UNIT
<b>POFFC</b>		
Poff	10.00	W

FEATURE	VALUE	UNIT
<b>PSBC</b>		
Psb	10.00	W

FEATURE	VALUE	UNIT
<b>PTOC</b>		
Pto	9.00	W

FEATURE	VALUE	UNIT
<b>GENERAL</b>		
Main Power Supply	230-1-50	
Refrigerant	R410A	
Refr. Line	5,0 m	m
Mounting	Ducted	