



PRODUCT PERFORMANCE RATING

Document ID 050520201636-12242323

Issued on 5 May 2020

This product is certified by Eurovent Certita Certification as mentioned on

Certificate N° 94.01.198

This document is valid at the date of issue - **Check the current validity on www.eurovent-certification.com**

Product	Air Conditioners / Climatiseurs (AC)
Product type	Comfort air conditioner below 12 kW/ air-cooled/ split/ reversible
Brand	FUJITSU
Range	AGY**L
Product référence	AOYG12LVCA/AGYG12LVCA

This performance certificate is delivered for the following project:

Project Name	Company	Project reference	Project location
PARAPETNI UREDJAJI		BEOGRAD	Serbia

FEATURE	VALUE	UNIT
STANDARD COOLING/COOLING PL COND A		
Pc	3.50	kW
Pec	0.94	kW
EER	3.72	



PRODUCT PERFORMANCE RATING

Document ID 050520201636-12242323

Issued on 5 May 2020

This product is certified by Eurovent Certita Certification as mentioned on

Certificate N° 94.01.198

This document is valid at the date of issue - **Check the current validity on www.eurovent-certification.com**

FEATURE	VALUE	UNIT
STANDARD HEATING		
Ph	4.50	kW
Peh	1.19	kW
COP	3.78	

FEATURE	VALUE	UNIT
ACOUSTIC		
LwO env	64	dB(A)
Lwl env	55	dB(A)

FEATURE	VALUE	UNIT
COOLING PL CONDB		
Pc @ 30°C	2.58	kW
EER @ 30°C	5.19	



PRODUCT PERFORMANCE RATING

Document ID 050520201636-12242323

Issued on 5 May 2020

This product is certified by Eurovent Certita Certification as mentioned on

Certificate N° 94.01.198

This document is valid at the date of issue - **Check the current validity on www.eurovent-certification.com**

FEATURE	VALUE	UNIT
COOLING PL CONDC		
Pc @ 25°C	1.73	kW
EER @ 25°C	8.65	

FEATURE	VALUE	UNIT
COOLING PL CONDD		
Pc @ 20°C	1.63	kW
EER @ 20°C	13.36	

FEATURE	VALUE	UNIT
SEASONAL EFFICIENCY IN COOLING		
Pdesignc	3.50	kW
SEER	6.50	
Qce	188.00	kWh/annum
SEER Class	A++	



PRODUCT PERFORMANCE RATING

Document ID 050520201636-12242323

Issued on 5 May 2020

This product is certified by Eurovent Certita Certification as mentioned on

Certificate N° 94.01.198

This document is valid at the date of issue - **Check the current validity on www.eurovent-certification.com**

FEATURE	VALUE	UNIT
HEATING PL CONDA		
Ph @ -7°C	3.36	kW
COP @ -7°C	2.47	

FEATURE	VALUE	UNIT
HEATING PL CONDB		
Ph @ +2°C	2.05	kW
COP @ 2°C	3.86	

FEATURE	VALUE	UNIT
HEATING PL CONDC		
Ph @ +7°C	1.54	kW
COP @ +7°C	5.86	

FEATURE	VALUE	UNIT
HEATING PL CONDD		
Ph @ +12°C	1.84	kW
COP @ +12°C	6.85	



PRODUCT PERFORMANCE RATING

Document ID 050520201636-12242323

Issued on 5 May 2020

This product is certified by Eurovent Certita Certification as mentioned on

Certificate N° 94.01.198

This document is valid at the date of issue - **Check the current validity on www.eurovent-certification.com**

FEATURE	VALUE	UNIT
HEATING AVERAGE CLIMATE		
Pdesignh	3.80	kW
SCOP	4.00	
SCOP Class	A+	
Qhe	1330.00	kWh/annum

FEATURE	VALUE	UNIT
BIVALENT POINT		
Tbiv	-7	°C
COP @ Tbiv	2.47	
Ph TBiv	3.36	kW

FEATURE	VALUE	UNIT
TOL RUNING TEST		
TOL	-15.00	°C
COP @ TOL	2.31	
Ph @ TOL	3.11	kW



PRODUCT PERFORMANCE RATING

Document ID 050520201636-12242323

Issued on 5 May 2020

This product is certified by Eurovent Certita Certification as mentioned on

Certificate N° 94.01.198

This document is valid at the date of issue - **Check the current validity on www.eurovent-certification.com**

FEATURE	VALUE	UNIT
POFFC		
Poff	9.00	W

FEATURE	VALUE	UNIT
PSBC		
Psb	9.00	W

FEATURE	VALUE	UNIT
PTOC		
Pto	14.00	W

FEATURE	VALUE	UNIT
GENERAL		
Main Power Supply	230-1-50	
Refrigerant	R410A	
Refr. Line	5,0 m	m
Mounting	Floor standing	