



# PRODUCT PERFORMANCE RATING

Document ID 050520201636-12242324

Issued on 5 May 2020

This product is certified by Eurovent Certita Certification as mentioned on

**Certificate N° 94.01.198**

This document is valid at the date of issue - **Check the current validity on [www.eurovent-certification.com](http://www.eurovent-certification.com)**

Product	Air Conditioners / Climatiseurs (AC)
Product type	Comfort air conditioner below 12 kW/ air-cooled/ split/ reversible
Brand	FUJITSU
Range	AGY**L
Product référence	AOYG14LVLA/AGYG14LVCA

This performance certificate is delivered for the following project:

Project Name	Company	Project reference	Project location
PARAPETNI UREDJAJI		BEOGRAD	Serbia

FEATURE	VALUE	UNIT
<b>STANDARD COOLING/COOLING PL COND A</b>		
Pc	4.20	kW
Pec	1.14	kW
EER	3.68	



# PRODUCT PERFORMANCE RATING

Document ID 050520201636-12242324

Issued on 5 May 2020

This product is certified by Eurovent Certita Certification as mentioned on

**Certificate N° 94.01.198**

This document is valid at the date of issue - **Check the current validity on [www.eurovent-certification.com](http://www.eurovent-certification.com)**

FEATURE	VALUE	UNIT
<b>STANDARD HEATING</b>		
Ph	5.20	kW
Peh	1.44	kW
COP	3.61	

FEATURE	VALUE	UNIT
<b>ACOUSTIC</b>		
LwO env	65	dB(A)
LwI1 env	58	dB(A)

FEATURE	VALUE	UNIT
<b>COOLING PL CONDB</b>		
Pc @ 30°C	3.09	kW
EER @ 30°C	5.09	



# PRODUCT PERFORMANCE RATING

Document ID 050520201636-12242324

Issued on 5 May 2020

This product is certified by Eurovent Certita Certification as mentioned on

**Certificate N° 94.01.198**

This document is valid at the date of issue - **Check the current validity on [www.eurovent-certification.com](http://www.eurovent-certification.com)**

FEATURE	VALUE	UNIT
<b>COOLING PL CONDC</b>		
Pc @ 25°C	1.99	kW
EER @ 25°C	8.42	

FEATURE	VALUE	UNIT
<b>COOLING PL CONDD</b>		
Pc @ 20°C	2.03	kW
EER @ 20°C	12.38	

FEATURE	VALUE	UNIT
<b>SEASONAL EFFICIENCY IN COOLING</b>		
Pdesignc	4.20	kW
SEER	6.40	
Qce	230.00	kWh/annum
SEER Class	A++	



# PRODUCT PERFORMANCE RATING

Document ID 050520201636-12242324

Issued on 5 May 2020

This product is certified by Eurovent Certita Certification as mentioned on

**Certificate N° 94.01.198**

This document is valid at the date of issue - **Check the current validity on [www.eurovent-certification.com](http://www.eurovent-certification.com)**

FEATURE	VALUE	UNIT
<b>HEATING PL CONDA</b>		
Ph @ -7°C	4.16	kW
COP @ -7°C	2.49	

FEATURE	VALUE	UNIT
<b>HEATING PL CONDB</b>		
Ph @ +2°C	2.53	kW
COP @ 2°C	3.85	

FEATURE	VALUE	UNIT
<b>HEATING PL CONDC</b>		
Ph @ +7°C	1.75	kW
COP @ +7°C	5.78	

FEATURE	VALUE	UNIT
<b>HEATING PL CONDD</b>		
Ph @ +12°C	2.18	kW
COP @ +12°C	6.39	



# PRODUCT PERFORMANCE RATING

Document ID 050520201636-12242324

Issued on 5 May 2020

This product is certified by Eurovent Certita Certification as mentioned on

**Certificate N° 94.01.198**

This document is valid at the date of issue - **Check the current validity on [www.eurovent-certification.com](http://www.eurovent-certification.com)**

FEATURE	VALUE	UNIT
<b>HEATING AVERAGE CLIMATE</b>		
Pdesignh	4.70	kW
SCOP	4.00	
SCOP Class	A+	
Qhe	1645.00	kWh/annum

FEATURE	VALUE	UNIT
<b>BIVALENT POINT</b>		
Tbiv	-7	°C
COP @ Tbiv	2.49	
Ph TBiv	4.16	kW

FEATURE	VALUE	UNIT
<b>TOL RUNING TEST</b>		
TOL	-15.00	°C
COP @ TOL	2.20	
Ph @ TOL	3.02	kW



# PRODUCT PERFORMANCE RATING

Document ID 050520201636-12242324

Issued on 5 May 2020

This product is certified by Eurovent Certita Certification as mentioned on

**Certificate N° 94.01.198**

This document is valid at the date of issue - **Check the current validity on [www.eurovent-certification.com](http://www.eurovent-certification.com)**

FEATURE	VALUE	UNIT
<b>POFFC</b>		
Poff	9.00	W

FEATURE	VALUE	UNIT
<b>PSBC</b>		
Psb	9.00	W

FEATURE	VALUE	UNIT
<b>PTOC</b>		
Pto	19.00	W

FEATURE	VALUE	UNIT
<b>GENERAL</b>		
Main Power Supply	230-1-50	
Refrigerant	R410A	
Refr. Line	5,0 m	m
Mounting	Floor standing	