



# PRODUCT PERFORMANCE RATING

Document ID 050520201527-12243512

Issued on 5 May 2020

This product is certified by Eurovent Certita Certification as mentioned on

**Certificate N° 94.01.198**

This document is valid at the date of issue - **Check the current validity on [www.eurovent-certification.com](http://www.eurovent-certification.com)**

Product	Air Conditioners / Climatiseurs (AC)
Product type	Comfort air conditioner below 12 kW/ air-cooled/ split/ reversible
Brand	FUJITSU
Range	AUY**L
Product référence	AOYG12LALL/AUYG12LVLB

This performance certificate is delivered for the following project:

Project Name	Company	Project reference	Project location
AUYG12LVLB - AOYG12LALL		BEOGRAD	Serbia

FEATURE	VALUE	UNIT
<b>STANDARD COOLING/COOLING PL COND A</b>		
Pc	3.50	kW
Pec	1.05	kW
EER	3.33	



# PRODUCT PERFORMANCE RATING

Document ID 050520201527-12243512

Issued on 5 May 2020

This product is certified by Eurovent Certita Certification as mentioned on

**Certificate N° 94.01.198**

This document is valid at the date of issue - **Check the current validity on [www.eurovent-certification.com](http://www.eurovent-certification.com)**

FEATURE	VALUE	UNIT
<b>STANDARD HEATING</b>		
Ph	4.10	kW
Peh	1.11	kW
COP	3.69	

FEATURE	VALUE	UNIT
<b>ACOUSTIC</b>		
LwO env	61	dB(A)
LwI1 env	49	dB(A)

FEATURE	VALUE	UNIT
<b>COOLING PL CONDB</b>		
Pc @ 30°C	2.58	kW
EER @ 30°C	5.69	



# PRODUCT PERFORMANCE RATING

Document ID 050520201527-12243512

Issued on 5 May 2020

This product is certified by Eurovent Certita Certification as mentioned on

**Certificate N° 94.01.198**

This document is valid at the date of issue - **Check the current validity on [www.eurovent-certification.com](http://www.eurovent-certification.com)**

FEATURE	VALUE	UNIT
<b>COOLING PL CONDC</b>		
Pc @ 25°C	1.97	kW
EER @ 25°C	8.80	

FEATURE	VALUE	UNIT
<b>COOLING PL CONDD</b>		
Pc @ 20°C	1.91	kW
EER @ 20°C	9.74	

FEATURE	VALUE	UNIT
<b>SEASONAL EFFICIENCY IN COOLING</b>		
Pdesignc	3.50	kW
SEER	6.20	
Qce	198.00	kWh/annum
SEER Class	A++	



# PRODUCT PERFORMANCE RATING

Document ID 050520201527-12243512

Issued on 5 May 2020

This product is certified by Eurovent Certita Certification as mentioned on

**Certificate N° 94.01.198**

This document is valid at the date of issue - **Check the current validity on [www.eurovent-certification.com](http://www.eurovent-certification.com)**

FEATURE	VALUE	UNIT
<b>HEATING PL CONDA</b>		
Ph @ -7°C	3.72	kW
COP @ -7°C	2.61	

FEATURE	VALUE	UNIT
<b>HEATING PL CONDB</b>		
Ph @ +2°C	2.54	kW
COP @ 2°C	4.21	

FEATURE	VALUE	UNIT
<b>HEATING PL CONDC</b>		
Ph @ +7°C	1.75	kW
COP @ +7°C	5.69	

FEATURE	VALUE	UNIT
<b>HEATING PL CONDD</b>		
Ph @ +12°C	2.12	kW
COP @ +12°C	6.35	



# PRODUCT PERFORMANCE RATING

Document ID 050520201527-12243512

Issued on 5 May 2020

This product is certified by Eurovent Certita Certification as mentioned on

**Certificate N° 94.01.198**

This document is valid at the date of issue - **Check the current validity on [www.eurovent-certification.com](http://www.eurovent-certification.com)**

FEATURE	VALUE	UNIT
<b>HEATING AVERAGE CLIMATE</b>		
Pdesignh	4.20	kW
SCOP	4.10	
SCOP Class	A+	
Qhe	1431.00	kWh/annum

FEATURE	VALUE	UNIT
<b>BIVALENT POINT</b>		
Tbiv	-7	°C
COP @ Tbiv	2.61	
Ph TBiv	3.72	kW

FEATURE	VALUE	UNIT
<b>TOL RUNING TEST</b>		
TOL	-15.00	°C
COP @ TOL	2.46	
Ph @ TOL	3.29	kW



# PRODUCT PERFORMANCE RATING

Document ID 050520201527-12243512

Issued on 5 May 2020

This product is certified by Eurovent Certita Certification as mentioned on

**Certificate N° 94.01.198**

This document is valid at the date of issue - **Check the current validity on [www.eurovent-certification.com](http://www.eurovent-certification.com)**

FEATURE	VALUE	UNIT
<b>POFFC</b>		
Poff	9.00	W

FEATURE	VALUE	UNIT
<b>PSBC</b>		
Psb	9.00	W

FEATURE	VALUE	UNIT
<b>PTOC</b>		
Pto	4.00	W

FEATURE	VALUE	UNIT
<b>GENERAL</b>		
Main Power Supply	230-1-50	
Refrigerant	R410A	
Refr. Line	5,0 m	m
Mounting	Cassette	