



# PRODUCT PERFORMANCE REPORT

Document ID 1534344745  
 Issued on August 15th, 2018

**PROJECT IDENTIFICATION** - This product performance report is delivered for:

Name **Viacom VS**  
 Company **Viacom VS**  
 Project reference **Fujitsu Website**  
 Project location **Serbia and Montenegro**

**PRODUCT IDENTIFICATION**

Certification Diploma N° **94.01.198**  
 Brand **FUJITSU**  
 Range **ASY\*\*L**  
 Product type **Comfort Air Conditioners / up to 12 kW / Air cooled / Split / Reverse cycle**  
 Product reference **AOYG12LTC / ASYG12LTC**

Important notice:

- I. Data featured in this report are valid at the date of issue. The scope of this product performance report does not include all certified data that can be checked at <http://www.eurovent-certification.com>
- II. This product performance report is valid only for above product features and should not be referred to as a Diploma.

FEATURE	VALUE	UNIT
<b>Acoustic</b>		
LwO env	64	dB(A)
Lw1 env	60	dB(A)
<b>Bivalent Point</b>		
Tbiv	-10	Å°C
COP @ Tbiv	2.52	
Ph TBiv	4.0	kW
<b>General</b>		
Mounting	Wall mounted	
MPS	230-1-50	
Refrigerant	R410A	
Refr. Line	5,0 m	m
<b>Heating 14511</b>		
Ph @+7	4.0	kW
COP @+7	4.4	
<b>Heating Average Climate</b>		
Pdesignh	4.0	kW
SCOP	4.6	
SCOP Class	A++	
Qhe	1217.0	kWh/annum
<b>Pck</b>		
Pck	11.0	W
<b>Poffc</b>		



# PRODUCT PERFORMANCE REPORT

Document ID 1534344745  
Issued on August 15th, 2018

FEATURE	VALUE	UNIT
Poff	5.0	W
<b>Poffh</b>		
Poffh	29.0	W
<b>Psb</b>		
Psb	5.0	W
<b>Ptoc</b>		
Pto	11.0	W
<b>Seasonal Efficiency in Cooling</b>		
Pdesignc	3.5	kW
SEER	8.5	
SEER Class	A+++	
Qce	144.0	kWh/annum
<b>Thermal</b>		
EER @+35	4.12	
<b>TOL Runing Test</b>		
TOL	-20.0	Â°C
COP @ TOL	1.84	
Ph @ TOL	3.63	kW